



CERTIFICATE OF COMPLIANCE

Certificate Number: SGSNA/24/GER/00023X

Contract Number: 802224

Certificate Project Number: GER-CERT241000092

Certified Product: Expert Power Control

Trademarks: GUDE

Model(s): 1121-1, 7-1121, 00112110, 1141-1, 7-1141, 00114110

Technical Data:
1121-1 / 7-1121 / 00112110:
Input : IEC C14, 100-240 VAC, 50/60 Hz, max. 10 A,
G-fuse 5x20mm 10A/250V time lag
Output: 2xIEC C13, 100-240 Vac, 50/60 Hz, max. 10 A;
1141-1 / 7-1141 / 00114110:
Input : IEC C14, 100-240 VAC, 50/60 Hz, max. 10 A,
G-fuse 5x20mm 10A/250V time lag
Output: 4xIEC C13, 100-240 Vac, 50/60 Hz, max. 10 A

Certificate Holder: GUDE Systems GmbH
Von-der Wettern-Str. 23, 51149, Köln, Germany

This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at www.sgs.com or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:


UL 62368-1, Ed. 3 dated December 13, 2019
CAN/CSA C22.2 No. 62368-1:19

Certification Condition

1. The system is to be installed, switched on and maintained only by suitably trained and qualified personnel in accordance with the installation instructions provided with the EUT.
2. The maximal acceptable operating temperature is +50°C for EPC 7-1141 and +45°C for EPC 7-1121.

Authorized by:

Effective date: 14 November 2024



John Luong
Certifier



Certification Body

Connectivity & Products, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com

