

CERTIFICATE OF COMPLIANCE

Certificate Number: SGSNA/23/GER/00010

Contract Number: 802224

Certificate Project Number: GER-CERT230900082

Certified Product: Expert Power Control

Trademarks: GUDE

Model(s): 7-8021-1 R2 7-8021-2 R2 7-8021-6 R2 7-8031-1 R2 7-8031-2 R2 7-8031-6 R2 7-8041-1 R2 7-8041-2 R2 7-8025-1 R2 7-8025-2 R2 7-8025-6 R2 7-8035-1 R2 7-8035-2 R2 7-8035-6 R2 7-8045-1 R2 7-8045-2 R2


Technical Data: Input: C20
100-240 VAC, 50/60 Hz, max. 12A; Output: 7-8021-1 R2 and 7-8025-1 R2: 4x IEC C13, 100-240 VAC, 50/60 Hz, max. 10A;
7-8021-2 R2 and 7-8025-2 R2: 4x IEC C13 Lock, 100-240 VAC, 50/60 Hz, max. 10A;
7-8021-6 R2 and 7-8025-6 R2: 4x NEMA 5-15, 100-240 VAC, 50/60 Hz, max. 12A;
7-8031-1 R2 and 7-8035-1 R2: 8x IEC C13, 100-240 VAC, 50/60 Hz, max. 10A;
7-8031-2 R2 and 7-8035-2 R2: 8x IEC C13 Lock, 100-240 VAC, 50/60 Hz, max. 10A;
7-8031-6 R2 and 7-8035-6 R2: 8x NEMA 5-15, 100-240 VAC, 50/60 Hz, max. 12A;
7-8041-1 R2 and 7-8045-1 R2: 12x IEC C13, 100-240 VAC, 50/60 Hz, max. 10A;
7-8041-2 R2 and 7-8045-2 R2: 12x IEC C13 Lock, 100-240 VAC, 50/60 Hz, max. 10A

Certificate Holder: GUDE Systems GmbH
Von-der Wetter-Str. 23, 51149, Köln, Germany

This certificate supercedes previous certificates issued with the same certificate number. Certification is valid when products are indicated on the SGS directory of certified products at www.sgs.com or using the QR code below. The product is certified according to ISO/IEC Guide 17067, Conformity assessment - Fundamentals of product certification, System 3, and in accordance with:

UL 62368-1, Ed. 3 dated December 13, 2019
CAN/CSA C22.2 No. 62368-1:19

Authorized by:



John Luong

Effective date: 18 October 2023



Certification Body

Connectivity & Products, a division of SGS North America Inc.
620 Old Peachtree Road, Ste. 100, Suwanee, GA 30024, USA
t +1 770 570 1800 f +1 770 277 1240 www.sgs.com

